

## 102. Recommended spare parts: SEG

### 50/60 Hz

#### Customer Information

Project title:	Customer name:
Reference number:	Customer number:
Customer contact:	Customer phone number: ( )
	Fax number: ( )

#### Pump information

#### Quotation made by

Type:		
Model:		
P.c.		
IP68	∇	m
Hmax:	m	Qmax: l/s
P1: kW		P2: kW
	~	A
n: min <sup>-1</sup>	Cosφ :	
Weight: kg	Tmax. : °C	
-I- opr.: μF	Hz	
	Insul.class:	
Made in Tatabanya. Hungary		

98807792

CE 0197 GRUNDFOS DK-8850 Bjerringbro Denmark

Company name:

Prepared by:

Phone number: ( )

Fax number: ( )

Date:

Quote number:

#### Recommended spare parts

Kit - Spare - Bulk	Recommended service parts						Product number
	1 pump		2 to 3 pumps		4 to 7 pumps		
	2 years units per pump	5 years units per pump	2 years units per pump	5 years units per pump	2 years units per pump	5 years units per pump	
Kit, Shaft seal	1	2	2	3	4	8	
Kit, O-ring	1	2	2	3	4	8	
Kit, Impeller	0	1	0	2	0	4	
Kit, Bearing	0	1	0	2	0	4	
Kit, Grinder	0	1	0	2	0	4	
Kit, Dry-running sensor*	0	1	0	1	0	1	
Kit, level sensor*	0	1	0	1	0	1	

\* Only for AUTO<sub>ADAPT</sub>.

Above recommendations are based on:

Agitators running in normal operation should be checked every 3000 operating hours or at least once a year.

If the stirred liquid is very muddy or sandy, check the pump at shorter intervals.